

## Ohio EPA - Daily Discharge Monitoring Report - Form 4500

FACILITY: Ohio Valley Coal Co Powhatan No 6 Mine \* PERMIT NUMBER: 01L00046\*DD  
 LOCATION: Intersect St Rte 148 and Rd 86 MONITORING PERIOD: 2008-01-01 To: 2008-01-31

## GENERAL REPORT COMMENT:

Flows for outfall 001 were estimated from the use of a 400 gpm pump.

## PARAMETER COMMENTS:

| Station Code | Parameter Name         | Parameter Code | Date       | Unit | Comment   |
|--------------|------------------------|----------------|------------|------|---|
| 001          | Flow Rate              | 50050          | 2008-01-21 | 4108 | FLOW ESTIMATED AT 0.384 MGD.  |
| 001          | Flow Rate              | 50050          | 2008-01-22 | 4108 | FLOW ESTIMATED AT 0.576 MGD.  |
| 001          | Flow Rate              | 50050          | 2008-01-23 | 4108 | FLOW ESTIMATED AT 0.192 MGD.  |
| 001          | pH                     | 00400          | 2008-01-21 | 6653 | NO SAMPLE TAKEN   |
| 001          | pH                     | 00400          | 2008-01-22 | 6653 | NO SAMPLE TAKEN   |
| 001          | Total Suspended Solids | 00530          | 2008-01-21 | 4106 | NO SAMPLE TAKEN   |
| 001          | Total Suspended Solids | 00530          | 2008-01-22 | 4106 | NO SAMPLE TAKEN   |
| 001          | Iron, Total (Fe)       | 01045          | 2008-01-21 | 4107 | NO SAMPLE TAKEN   |
| 001          | Iron, Total (Fe)       | 01045          | 2008-01-22 | 4107 | NO SAMPLE TAKEN   |
| 001          | Manganese, Total (Mn)  | 01055          | 2008-01-21 | 4107 | NO SAMPLE TAKEN   |
| 001          | Manganese, Total (Mn)  | 01055          | 2008-01-22 | 4107 | NO SAMPLE TAKEN   |
| 002          | Flow Rate              | 00056          | 2008-01-03 | 4109 | AB-HOUR METER IS USED TO DETERMINE FLOW. METER MALFUNCTIONED. WAS REPLACED. |